Lafayette Water Works Plant

Water Our Most Precious Resource FEBRUARY 2012

Operations

Canal

- Changed filters on the hypo generator
- Flushed out Fluoride discharge line
- Installed new spill mats on Fluoride pump skid

Glick Station

- Replaced Cl2 probe tip and electrolyte
- Calibrated Cl2 analyzer
- · Greased overhead door
- Replaced bulbs on well towers

CPHSS

- Assisted Maintenance and cross trained by greasing pump bearings
- Touch up paint on pump room columns and roof drain pipes

Elevated Towers

- Replaced CI2 probe tip and electrolyte at HLET
- Calibrated Cl2 analyzer
- Investigated phone problem at HLET
- Investigated Cl2 analyzer pH reading problem
- Greased overhead door at PSET
- Greased overhead door at HLET
- Investigated phone line problem at USET

MISC.

- Organized SCADA computer files
- Assisted Inventory
 Manager with moving
 new meters into the
 building
- Repaired chair for use in Operations office
- Research whether to order parts or purchase new hypo pump head

- Meeting with water treatment chemical salesman
- Meeting with water treatment feed pump salesman
- Completed two water quality reports for kidney dialysis company
- Attended AWWA conference in Indianapolis
- Updated Operations Calendar for 2012
- Collected and tested 60 distribution bacteria samples for TCR Report
- Collected and tested 4
 distribution Fluoride split
 samples for State NaF
 Report
- Collected samples for the air stripper influent and effluent and C-7 and C-8
- NPDES Report
- Collected quaternary samples for TTHM/HAA5
- Change electrode solution in pH meter and change out buffer solution

After hours and weekend service request calls that are handled by our System Operators and On-Call personal totaled 92 this month.

Maintenance

Canal

- Installed new diagram on C-10 well valve
- Cleaned out fluoride line, replumbed vat

Glick Station

- Adjusted packing on G-2 & G-4
- Cleaned flow meter
- Repaired busted Po4 line
- Cleaned valve vaults G-1 & G-4

CPHSS

- Greases all service pumps
- Laser aligned all service pumps
- Organized network cables and Traffic improvement antenna cables in Boiler room

Elevated Towers

 Installed new W-1500 board at PSET

MISC.

- Bi-Weekly inspections at all Water Works facilities
- Ran Gen-Sets
- Cleaned, fueled and organized maintenance vehicles
- Helped Customer
 Service Dept installing
 new water meters

Average pumping: 7.8mgd AGIII3

Maximum Pumping! 8.8mgd L- UVII ZIOZ

Minimum Pumping: 4.6mgd L- UVII ZIOZ

MINIMUM PUMPING: 4.6mgd AGIII3

Construction

- Repaired 4 broken mains
- ♦ Installed 48 new services, 30 @ Hawthorne
- Repaired 4 services and updated 4 services
- Made 5 valve box repairs
- ♦ Replaced 1 fire hydrant
- ♦ Raised 2 meter pits
- Made repairs to meter pits throughout the system due to winter wear and tear
- Filled digs up with needed materials to get through the winter season
- Cleaned and organized trucks and trailers
- Performed needed maintenance on vehicles and equipment
- ♦ Plowed snow in Area 1
- Assisted the Customer Service Department were needed
- Assisted with Inventory stocking and recording
- Assisted the Street Department where needed
- Total Locates performed 445, 26 were emergency call requests and 6 were Contractor Assisted
- Our Water Facility
 Inspector preformed 8
 hydrostatic test, 16
 bacteria tests and 10
 fire line hard flushes,
 assisted Contractors
 and our Construction
 Crews where needed
- Backflow Program;
 60 Inspections, 28
 Compliance letters sent and 204 devices tested and data
 Entered

<u>Customer</u> Service

CSFT responded the following requests/services:

- Responded to 1 discolored water call
- ♦ Changed 191 meters
- Meters repaired 3 and raised 2 meter pits
- Service applications308
- ♦ Account finals 143
- ♦ Turn-off for nonpayments 301
- Check meter readings59
- Completed work orders 338
- Blue tags for return service 42
- Zero Consumption Runs 27
- UBO radioed 437 requests to CSFT's
- ♦ 159 MXU Radio Readers installed
- Our 3 Service Techs drove an average of 157 miles per day this month